

FireWarden Series Configuration

NOT-BG12LX Addressable Manual Pull Station

To Central Station Over Telephone Network



SLC Loop

NP-100 Photo Detector



NI-100 Ion Detector



NH-100 Thermal Detector



NDM-100 Dual Monitor Module



DNR Duct Detector



NMM-100/NMM-100P



NZM-100-6



NCM-100 Control Module

24VDC

ANN-BUS

EIA-232



FDU-80



N-ANN-80



NZM-100 2-Wire Detector Monitor Module



2151 Photo Detector

PRN-6 Printer



EIA-485 Loop from FireWarden-100-2

EIA-485



FirstCommand™ Voice Evacuation System



FirstCommand™ NFC-125DA

Up to Eight Speaker Circuits

